

Flashni (FL)



Flashni (FL) : 0832-CPD-0133 (18~28V)
EN54-3 Fire Alarm Device - Sounder
Dispositif d'alarme incendie EN54-3 – Avertisseur d'incendie
EN54-3 Feueralarmgerät – Töner
Dispositivo di allarme antincendio a norma EN54-3 - Sirena
EN54-3 Brandalarm - sounder
Dispositivo de alarma de incendios EN54-3 – Timbre de alarma
EN54-3 Brandvarnare – Signalgivare
EN54-3 Urządzenie systemów SAP - Sygnalizator

9 ~ 15VDC	EN54-3	24V from (18 ~ 28VDC)
		111 mA max
		0.28mm² - 2.5mm²
		Type A - 10 0° ~ +55 0°
		ABS V0
		Type A = IP21C
		6
		32

Product exceeds minimum requirements of EN54-3

See www.fullleon.com
Le produit dépasse les exigences minimum de EN54-3
Voir www.fullleon.com
Das Erzeugnis erfüllt die Mindestanforderungen von EN54-3.
Siehe www.fullleon.com
Il prodotto supera i requisiti minimi previsti dalla norma EN54-3
Vedi www.fullleon.com
Product overtreft de minimale vereisten van EN54-3.
Zie www.fullleon.com
El producto excede los requisitos mínimos de la norma EN54-3
Véase www.fullleon.com
Produkten överträffar minsta krav enligt EN54-3
Se www.fullleon.com
Parametry techniczne produktu przekraczają minimalne wymagania normy PN EN54-3, szczegółly www.fullleon.com

